

REPORT LINK	SEPARATING ELEMENT	JOINT/SERVICE SUMMARY	FIRE RESISTANCE LEVEL (FRL)	STANDARD COMPLIANCE	ORIENTATION	SEAL CONFIGURATION			REPORT TYPE/NUMBER	
						BOTH FIRE & NON-FIRE SIDE	FIRE SIDE ONLY	NON-FIRE SIDE ONLY	FIRE TEST	ASSESS- MENT
		PLASTERBOARD - CONTROL JOINTS								
24A	90mm/96mm thick wall - 1x13mm & 1x16mm Fire-rated Plasterboard wall Joints*	13mm-20mm wide x 13mm deep Joints & 15mm-20mm wide x 16mm deep Joints at head, base, perimeter and centre of wall (Centre wall control Joint 15mm wide x 13mm deep & 15mm wide x 16mm deep.)	up to -/120/90**	AS 1530.4 (2014)	Horizontal & Vertical	Yes	No	No	FRT 180013.2	NA
24B	116mm thick wall - 2x13mm Fire-rated Plasterboard wall Joints*	10mm, 20mm & 22mm wide x 26mm deep Joints, at head, base, perimeter and centre of wall. (Centre wall control Joint 22mm wide x 25mm deep.)	-/120/120	AS 1530.4 (2014)	Horizontal & Vertical	Yes	No	No	56967400.1	NA
		CONCRETE & MASONRY - CONTROL JOINTS								
28A	120mm-175mm Concrete & Masonry wall Joints (various seal configurations)*	10mm-40mm wide Joints sealed both sides, 10mm wide Joints sealed fire side only & non-fire side only (min. 120mm, min.150mm & min 175mm thick walls.) 20mm & 30mm wide Joints sealed non-fire side only (min.150mm & min 175mm thick walls only.)	up to -/240/240**	AS 1530.4 (2014) & 4072.1 (2005)	Vertical	Yes	Yes	Yes	NA	FC 21382 -01-01
28B	120mm thick Concrete wall Joints sealed both sides*	10mm wide x 10mm deep & 20mm, 30mm & 40mm wide Joints at conventional 2:1 width:depth ratio, sealed both sides.	-/240/120	AS 1530.4 (2014)	Vertical	Yes	No	No	FRT 180011a.1	NA
28C	120mm thick Concrete wall Joints sealed fire side only & non-fire side only*	10mm wide x 10mm deep, 20mm & 30mm wide x various depth (increased) Joints sealed fire side only & non-fire side only.	up to -/240/120**	AS 1530.4 (2014)	Vertical	No	Yes	Yes	FRT 180400.1	NA

* See individual test or assessment data for information relating to control Joint configurations, penetrating services and wall/floor thickness.
 ** See individual test or appraisal data for information relating to FRL's for specific control Joints and service penetrations.
 Due to variations in fire rating results using different separating elements and thicknesses consult fire test/assessment reports for specific tested FRL's.